



ARCHITECTS

978 TRINITY ROAD, RALEIGH, NORTH CAROLINA 27607

MAIL TO: P.O. BOX 6468, RALEIGH, NC 27628-6468

919.859.7003 VOICE

919.859.7121 FACSIMILE

AQUATIC FACILITY REVIEW FOR COMPLIANCE WITH THE VIRGINIA GRAEME BAKER POOL AND SPA SAFETY ACT

FACILITY: River Rock Swim and Racket Club, 1401 Evans Road, Cary, NC

TYPE OF FACILITY: Wading Pool

PUMP: 0.5 hp Hayward Super Pump. Based on the manufacturer's pump curve, the maximum flow of this system is 55 gpm.

MAIN DRAINS: Two new 9x9 inch ASA FPK-50-809 VGB compliant sumps and AquaStar R914 cover/grates separated by 4 feet edge-to-edge. The cover/grates are rated for 560 gpm and are installed in accordance with the manufacturer's instructions.

SECONDARY
ENTRAPMENT

PROTECTION: Not required.

SKIMMERS: The skimmers do not have equalization lines.

VACUUM: The pool does not have a vacuum line.

CERTIFICATION: On the date of this letter the subject facility is in compliance with the Virginia Graeme Baker Pool and Spa Safety Act. Photographs of the facility and cut sheets of the devices noted in this letter are available upon request.

DATE: April 28, 2010

SIGNED:

